

Procurement Division 111 Maryland Avenue Rockville, Maryland 20850-2364 Phone 240-314-8430 Fax 240-314-8439

ADDENDUM 1

DATE: May 14, 2018

REFERENCE: City of Rockville

Invitation for Bid: IFB 42-18

Wootton Parkway Sidewalk Extension Project

Scheduled Submittal Deadline: Tuesday, May 22, 2018 at 02:00 P.M. (Eastern)

Please note the following additions, revisions, clarifications, corrections and/or deletions have been made to the above referenced Invitation for Bid (IFB):

Addition 1:

The following header is added by reference to the top right-hand corner of pages 55 through 82 of the Invitation to Bid:

IFB # 42-18 SECTION V

Clarification 1:

General information regarding the blocks for the existing retaining wall located in the adjacent stretch of Wootton Parkway that the proposed wall is required to match is provided below:

Manufacturer: Keystone

Style: Compac, Straightface

Cap Style: Universal Color: Desert Sand

Clarification 2:

Engineered, stamped drawings are not required for the proposed retaining wall. Refer to the contract documents for information. Notes for the retaining wall on drawing number 5 require submission of design shop drawings, details, and materials specifications of the manufacturer for review and approval. Signed and sealed plans are not stipulated as required. Construction of walls should follow the contract documents and the manufacturer requirements.

Clarification 3:

There is no geotechnical report for this project.

Addendum 1 IFB 42-18 Wootton Parkway Sidewalk Extension Project

Clarification 4:

An electrical permit will not need to be obtained from the City's Inspection Services Division for the streetlighting work. Work will be in accordance with the plans and specifications. Pepco inspection of underground lighting facilities will need to take place in accordance with the notes located on drawing number 16.

Please sign below to acknowledge receipt of addendum and return with your bid.		
Sincerely,		
Jonathan Pierson, CPSM, C.P.M. Principal Buyer		
Company Name	Authorized Signature	
Date		
JWP/jwp		